



Certificate of Conformity

Certificate: 17041-1S

Master Contract: LC 1231751

Project: 17041

Date Issued: April 24, 2019

Issued to: Victron Energy B.V.
De Paal 35
1351 JG Almere Haven
The Netherlands

Certification System Type 3
(ISO / IEC Guide 67)

The products listed below are eligible to bear the LabTest Certification Mark with adjacent indicator 'US', and the subject area as shown below.



Issued by:

Certification Manager

PRODUCTS

- Inverter
- Models: MultiPlus 12/3000/120-50 120V
MultiPlus 24/3000/70-50 120V
- Ratings:

Model number	DC IN Input Voltage range; Input current max	AC OUT	AC IN (range)	DC OUT	Apparent nominal output power (Sn)	Active nominal output power (Pn)
MultiPlus 12/3000/120-50 120V	9,5-17Vdc 250A	120Vac, 60Hz, 21A	95- 140Vac, 55-65Hz, 50A	13,2- 14,4Vdc 120A	3kVA	2,4kW
MultiPlus 24/3000/70-50 120V	19-33Vdc 125A	120Vac, 60Hz, 21A	95- 140Vac, 55-65Hz, 50A	26,4 – 28,8Vdc, 70A	3kVA	2,4kW

APPLICABLE REQUIREMENTS & SUBJECT AREA

- UL 458: 2015 (Ed.6)

CONDITIONS OF ACCEPTABILITY

- None

The 'US' indicator adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable UL Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.